

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 320

Date : 4/8/26

It is certified that an inspection team headed by Assistant
Engineer Sushmita Saini (Name of Officers
with designation) from PHED (Name of
Department/Office) inspected the Swami Vivekanand Govt.
model school, Hindoli (Name & Address of
the School) on 03/08/26 and found that the Tubewell
(Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of Six month.

Signature with Seal :

Name :

Designation :

Sushmita Saini
सहायक अभियन्ता
जन स्वास्थ्य अभियंत्रण विभाग
उपखण्ड देवदोली
Assistant Engineer
D.O. CODE- 32253

To

SWAMI VIVEKANAND

Govt. model school

Hindoli - 92140-82188

9985371312
(Name & Address of the Institution)

Sample test Result by FTIX

- | | | |
|--------------|-------|----------------------------|
| ① PH | - 7.0 | (Permissible Limit 4-11.0) |
| ② Alkalinity | - 200 | (" 0.0-600 PPM) |
| ③ Nitrate | - 0 | (" 0.0-100 PPM) |
| ④ Fluoride | - 0.5 | (" 0.0-2.0 PPM) |
| ⑤ Hardness | - 540 | (" 0.0-600 PPM) |